

Model based diagnostic module for a FCC pilot plant

Un système de diagnostic d'un pilote de FCC à base de modèles.

Benoit Celse¹, Sylvie Cauvin², Bruno Heim¹, Sylviane Gentil³, Louise Travé-Massuyès⁴

¹IFP-Lyon BP 3 - 69390 Vernaison, France, Benoit.Celse@ifp.fr

²IFP 1-4, avenue de Bois Préau - 92852 Rueil Malmaison, France, Sylvie.Cauvin@ifp.fr

³LAG BP46 - 38402 Saint Martin d'Hères Cedex 1, France, Sylviane.Gentil@inpg.fr

⁴LAAS-CNRS 7-avenue du Colonel Roche, 31077 Toulouse Cedex 4, France, Louise@laas.fr

Abstract

This paper presents a diagnostic module developed by IFP and tested off-line on a FCC (Fluid Catalytic Cracking) pilot plant. The method uses four successive complementary techniques. They enable to go step by step from the observations to a sentence in natural language describing the faults. First, a quantitative causal model is elaborated from a quantitative behavioural model. Causality is obtained from the structure of each equation. Then, global and local alarms are generated using residuals (differences between measures and outputs of the model) and fuzzy logic reasoning. Then, a hitting set algorithm is applied to determine sets of components or equipment which are suspected to have an abnormal behaviour. Finally, expert human operator knowledge about those components is used to identify the fault(s) and produce messages for the operators. This software is currently tested off-line on the FCC pilot plant at IFP. The performance of the diagnostic module is illustrated on four practical scenarios of abnormal behaviour. This work is conducted as part of the CHEM EC funding project.

Résumé

Ce papier présente le système de diagnostic ASCO (Aide à la Supervision et à la Conduite des Opérateurs) développé par l'IFP et testé hors ligne sur un pilote de FCC (Fluid Catalytic Cracking). Il fait successivement appel à quatre modules complémentaires. Ils permettent à partir d'un ensemble d'informations de fournir aux opérateurs un message indiquant la panne et ses conséquences. Le premier module permet de générer un modèle causal quantitatif de bon fonctionnement du procédé. Le second module effectue la détection de défauts : il génère des alarmes à partir des observations. Ces alarmes sont ensuite traitées par le module de localisation (algorithme de hitting set) qui élabore une liste de composants physiques, suspectés être défectueux. Finalement, la connaissance des experts sur ces composants est automatiquement traitée par le module d'identification qui génère un message envoyé à l'opérateur. Ce message décrit la défaillance, les actions à entreprendre pour maintenir l'opération ou pour la maintenance à effectuer, et les répercussions de la défaillance sur le procédé. Les résultats obtenus sont illustrés sur 4 scénarios réels de mauvais comportement. Ce travail a été mené dans le cadre du projet Européen CHEM.

NOMENCLATURE

CMS: Causal Model Structure
FCC: Fluid Catalytic Cracking
FDI: Fault Detection and Isolation
SCADA: System of Control And Data Acquisition
SRM : structural relation model

INTRODUCTION

Nowadays, process supervision is mainly performed by operators. The process is usually controlled with a SCADA involving an operator interface and an automatic shut down emergency system. Due to the increasing size and complexity of processes, the understanding of faults and their propagation becomes more and more

difficult. Therefore, it is essential to develop new computer tools that are able to detect faults, to isolate damaged equipment and to decide on accommodation and reconfiguration control strategies to deal with altered situations (Iserman and Ballé, 1997; Trave and Gentil, 1999; Blanke et al., 2003). As the aim of these tools is to help operators in their daily decisions, they must be designed with the scope of human-machine cooperation.

A Fluid Catalytic Cracking (FCC) unit is a refinery process which receives multiple feeds consisting of low value, high boiling point feedstocks. The FCC cracks these streams into valuable components such as gasoline and diesel. The FCC is extremely efficient with only about 5% of the feed used as fuel in the process.

Fluid catalytic cracking continues to play a key role in an integrated refinery as the primary conversion process. For many refiners, the cat cracker is the key to profitability in that the successful operation of the unit determines whether or not the refiner can remain competitive in today's market. Approximately 350 cat crackers are operating worldwide, with a total processing capacity of over 12,7 million barrels per day (Raider and Mari, 1996).

For this process, reliability is required to allow long-term operation between maintenance shutdowns (every 3-5 years typically). As much as 4000 t/h of hot catalyst is transported in the FCC system at up to 20-30 m/s, thereby requiring a robust process and mechanical design. Good unit operation and performance must be achieved to justify the refiner's investment and to minimise short payout times imposed by business aspects. Diagnostic tools must then be developed in order to improve the reliability and to prevent from shutdowns.

Normal operating condition models are now commonly used for fault detection (Frank and Ding 2000). However, for complicated processes, obtaining such a model may be tricky. Two types of models are generally developed for industrial plants:

1. material or energy balances established from process block diagrams and flowsheets that integrate operator knowledge of production rules. They are written from a production management standpoint and thus implement shop-scales balances.
2. complex, partial derivative non-linear analytical equations that are written by physicists. They are developed to obtain load diagrams or to build training simulators. They are not often available for real processes.

These two kinds of models are conceived for purposes other than supervision. Classic FDI (Fault Detection and Isolation) used in automatic control - generalised parity space, dedicated observers scheme or parameter estimation (Frank, 1990, 1991; Patton and Chen, 1991; Isermann, 1993) - are poorly suited to this type of representation. Classic diagnostic techniques for industrial processes are generally based on state variable representation and thus are not adapted to the supervision of a complete facility because of their constraining formalism and global analytical processing.

Moreover, keeping in mind that the objective of the model is diagnosis, specific modelling methods must be applied. It is commonly accepted that humans often refer to causal mental models for supporting explanation tasks and diagnosis (Rasmussen, 1993). An advantage of causal diagnostic computer tools to support human based supervision is their intrinsic explanatory capacity (Evsukoff et al., 2000) related to the match of the model with human mental representation structures. The causal model captures the influences between the variables of a process and supports qualitative and quantitative knowledge that can be interpreted by a diagnostic module. In particular, each influence is labelled in terms of physical component(s) of the process, which establishes a link between behavioural knowledge and hardware (Travé-Massuyès et al., 2001).

In the area of automatic control, change/fault detection and isolation problems are known as model-based FDI. Relying on an explicit model of the monitored plant, all model-based FDI methods (and many of the statistical diagnostic methods) require two steps. The first step generates inconsistencies between the actual and expected behaviour. Such inconsistencies, also called residuals, are 'artificial signals' reflecting the potential faults of the system. The second step chooses a decision rule for diagnosis. The check for inconsistency needs some form of redundancy. There are two types of redundancies, hardware redundancy and analytical redundancy. The former requires redundant sensors. It has been utilised in the control of such safety-critical systems as aircraft space vehicles and nuclear power plants. However, its applicability is limited due to the extra cost and additional space required. On the other hand, analytical redundancy (also termed functional, inherent or artificial redundancy) is achieved from the functional dependence among the process variables and is usually provided by a set of algebraic or temporal relationships among the states, inputs and outputs of the system. The essence of analytical

redundancy in fault diagnosis is to check the actual system behaviour against the system model for consistency. Any inconsistency expressed as residuals, can be used for detection and isolation purposes. The residuals should be close to zero when no fault occurs but show ‘significant’ values when the underlying system changes. The generation of the diagnostic residuals requires an explicit mathematical model of the system.

This paper presents a method which relies on analytical redundancy in order to detect, isolate and identify faults in a FCC pilot plant. This case study is chosen to evaluate the practical feasibility of the approach in terms of speed, accuracy, and computational complexity not only because it is a highly nonlinear, strongly coupled, multivariable system but also because it has a significant economic impact.

Our method uses four successive complementary techniques (Cauvin and Celse, 2004a, Cauvin and Celse, 2004b). They enable to go step by step from the observations to a sentence in natural language describing the faults:

- **Modelling:** A quantitative causal model is elaborated from a dynamic behavioural model of the process. This model can be used around one steady state. It describes quantitatively the influences among process variables. A possible representation of a causal model is a causal graph made of nodes and directed arcs. Nodes represent variables and arcs represent influences among variables. The information carried by the arcs is quantitative: gains for a static representation or transfer functions to take time into consideration (Leyval et al., 1994), (Travé-Massuyès et al., 2001).
- **Detection:** The model is used to calculate two references: given a variable x that influences a variable y , values for y can be generated either based on a model value for x (global reference) or based on a measured value for x (local reference). Values are propagated from node to node easily. The global reference indicates the consistency of the variables regarding exogenous variables (set-points, disturbances...). The local reference indicates the coherency regarding a local environment. Comparing measures with these references, the fault detection module determines whether measured variables have an abnormal behaviour or not (analytical redundancy). Alarms are generated using fuzzy logic.
- **Isolation:** The set of components associated to edges connected to variables which have an abnormal behaviour, known as *conflicts*, are interlined to determine the subsets of physical components that behave abnormally, i.e. the *diagnoses*.
- **Identification:** Each component is associated with semi-qualitative models of its abnormal behaviour obtained from the operator expert knowledge and expressed in the form of a fault/symptom tree. When a component is suspected by the isolation module, its fault/symptom tree is activated, symptoms are qualified by a signal analysis, faults and possible actions are identified and suggested to the operators.

The paper is organised as follows.

- Section 1 presents the causal modelling approach.
- Section 2 details the diagnostic module. It can be divided into three sub-modules for fault detection, isolation and identification.
- Section 3 presents several scenarios obtained with the FCC pilot plant.

1. Causal modelling

The aim of this section is to present how to obtain the quantitative causal graph. This model will be used in order to calculate references for the process which will be used by the detection module (cf. 2.1).

1.1 Description of the modelling approaches

1.1.1 Principles

The basic structure underlying a causal model is a directed graph¹, named the *causal graph*. The causal graph is made up of a set of nodes V and a set of directed arcs I . Nodes represent variables and arcs represent influences among the variables.

Graphs are a powerful mathematical tool (Murota, 1991) and have been used since the eighties to represent physical system properties. State-space representations of linear structured systems, for instance, can be easily transformed into a graph. The classical system properties, useful for control, such as controllability, finite and infinite zero structure, disturbance rejection and so on, can be expressed in graph theoretic terms. The most important results are summarised in the recent survey paper (Dion et al., 2003). In these control approaches, the state-space representation of the system is given, and the graph is generated easily: nodes correspond to state variables and edges are associated to the non zero parameters in the state and input matrices.

The problem which is solved in this paper is different since the model of the system is not assumed to be structured as a state-space representation. This work consists precisely in finding the model's structure from the set of non ordered relations, and expressing it as a graph. Even though the model's structure is intended to be used for diagnostic purposes, the model that we consider represents the normal behaviour. The relations thus describe the normal operating behaviour of the components. Qualitative digraphs have been used first by Kramer and Palowitch (1987) and after that by other authors (see for instance Maurya et al., 2003 for a recent work) for fault detection. The arcs contain knowledge about the signs of the influences, from which propagation of faults is deduced (too high or too low variables' values). This approach was extended to batch processes. Here, the model is dynamic and quantitative.

There are various types of knowledge sources that can be used to obtain a causal graph for a given process. The first is the empirical knowledge of operators and experts of the process behaviour. This type of knowledge is difficult to extract and to formalise (Heim et al., 2001; Leyval et al., 1994). It is subjective, as it is related to the experts' point of view. It is difficult to guarantee its completeness. The second is related to the description of the process by a set of differential-algebraic equations that define its behaviour. Using these equations, the causal graph is generated automatically (Travé-Massuyès and Pons, 1997) (Travé-Massuyès and Dague, 2003). Obtaining this kind of knowledge involves all the difficulty of physical modelling and needs further processing to generate the causal graph. This point is developed in this section.

1.1.2 Generation of the Causal graph

In this paper, the causal ordering framework of Iwasaki and Simon (1986) later extended within a graph theoretic framework (Porte et al., 1988) and in (Trave and Pons, 1997) for multiple mode systems has been adopted, due to its practical feasibility. This approach makes the most of its advantage by operating from the equations structure, hence only requiring a *structural relation model* (SRM) as initial knowledge

In the causal graph, a set of influences from variables v_i, \dots, v_n to variable y mean that a relationship $r(v_i, \dots, v_n, y)$ exists between these variables and that this relationship is expressed in such a way that y is computed from v_i, \dots, v_n values. A causal model can contain further qualitative and quantitative information. In the proposed approach, each influence is labelled with the physical components that underlie the relationship, called the *influence/relation support* (Cordier et al., 2000). This provides the *causal model structure*.

The three following properties are commonly accepted to characterise causality: *necessity* (effects have unique causes), *locality* (the effect is structurally close from the cause), *temporality* (the cause precedes the effect). Consequently, causality appears naturally in differential or difference equations in canonical form (Travé-

Massuyès and Dague, 2003), i.e. $\frac{dx_{n+1}}{dt} = f(x_1, \dots, x_n)$ or $x_{t+1}^{n+1} = g(x^1, \dots, x^n)_t$, for which it is commonly accepted that the left-side variable is causally dependent on the right side variables. This choice is not arbitrary, but is due to physical considerations. The same reasoning can be made for relations containing delays. If a

¹ Other equivalent representational forms could be used, such as an incidence matrix.

variable V influences a variable Y with a delay d , then Y is causally dependent on V . The difficulty comes from the algebraic equations that can give rise to algebraic loops and lead to non deterministic causal ordering.

Providing a full presentation of the theory is not the intention of this section, but rather explaining the different steps of the method using the following example.

Let's consider a set of equations E , of variables V . A variable is exogenous to a system Σ if it cannot be described with the help of the other variables of Σ . A variable that is not exogenous is endogenous and belongs to the set V_{endo}

$$E = \left\{ \begin{array}{l} e_1 : e_1(V_1, V_2, V_3, V_6) \\ e_2 : e_2(V_3, V_4, V_5) \\ e_3 : e_3(V_4, V_6) \\ e_4 : e_4(V_4, V_6, V_7) \end{array} \right\}$$

$$V = \{V_1, V_2, V_3, V_4, V_5, V_6, V_7\}$$

$$V_{endo} = \{V_3, V_4, V_5, V_6, V_7\}$$

$$V_{exo} = \{V_1, V_2\}$$

These equations constitute the Structural Relation Model (SRM). Five steps are necessary to produce the Causal Model Structure **CMS** from the previously obtained structural relation model (**SRM**). They are illustrated on the previous example by Figure 1.




Figure 1: Bipartite and directed graphs.

- (a) Bi-partite graph,
- (b) Just-determined bipartite graph,
- (c) Edges of (b) belonging to the perfect matching,
- (d) Perfect-matching,
- (e) Directed graph

The first step consists in generating a preliminary *bipartite graph*. A *bipartite graph* is an undirected graph in which nodes can be divided into two sets such that no edge connects nodes within the same set. Here, the two sets are the set of equations E and the set of variables V . The *bipartite graph* $G = (V \cup E, A)$ is hence defined,

in which a non-directed-edge $A(V_i, e_j)$ between V_i and e_j exists if, and only if, the variable V_i is involved in equation e_j : $V_i \in Var(e_j)$ (Figure 1-a).

The objective is then to determine for each equation e_j which variable is causally dependent on the other variables involved in e_j . This means that for instance an equation such that $e_j(V_1, V_2, V_3)$ is rearranged as following equation:

$$V_2 = g(V_1, V_3 \dots)$$

In this case, the variables on the right side V_1 and V_3 are the *direct causes* of the variable on the left side V_2 , which can also be interpreted as: V_2 's values can be computed from V_1 and V_3 values.

Causal ordering requires first of all to specify the exogenous variables of the **SRM** and moreover, it requires the **SRM** to be non degenerated, i.e. $n_E = n_V$ and *self-contained*. A system of n algebraic equations is self-contained if any proper subset of k ($k \leq n$) involves at least k variables. This notion can be compared to the definition of a just determined system that was introduced in (Cassar and Staroswiecki, 1997). This constraint can be understood as determining the number of endogenous variables that can be computed with the model. In practice, this can be used to draw the limits of the system and its environment, which means that some variables need to be considered as exogenous even if they are not so in reality. These variables are referred to as *pseudo-exogenous variables* in the following. They constitute the set $V_{pseudo.exo}$. This is an important point for a practical application. More than one causal graph can be built for the same **SRM** depending on the choice of the pseudo-exogenous variables. If the system is not self contained, the model has to be modified. Unger et al. (1995) gives a structural method to obtain a feasible model from a set of Differential Algebraic Equation (DAE).

For each exogenous or pseudo-exogenous variable in V_{exo} and $V_{pseudo.exo}$, \mathbf{E} must be increased with a so-called *exogenous equation* which affects a constant value to the variable, meaning that this variable is controlled by the system's environment. In the example, $(n_V = 7) \neq (n_E = 4)$. For real applications, practical considerations guide the choice of pseudo-exogenous variables. In our example, V_5 is chosen arbitrarily as a pseudo-exogenous variable. This choice has no consequence on the methodology further developed. \mathbf{E} is increased by 3 exogenous equations relative to variables V_1, V_2, V_5 to obtain a just-determined bipartite graph G_j (see Figure 1-b). The results presented in Figure 2 are obtained when V_5, V_3, V_7 (Or V_4 and V_6) are chosen as pseudo-exogenous variables, respectively.

Causal ordering results from determining a *perfect matching* in G_j . The *perfect matching* in a *bipartite graph* is a set of edges such that each edge is connected to only one node of each set of the *bipartite graph* and each node is connected to only one edge.

In the just determined bipartite graph (Figure 1-b), some edges obviously belong to the perfect matching. For instance when an equation involves only one variable (this is the case for instance of the pseudo-exogenous equations) and when a variable is involved in only one equation (case of variable V_7) (Figure 1-c). This is also the case of dynamic relations, since their causal interpretation is predefined, as mentioned above.

If the equation set \mathbf{E} does not contain any algebraic loop, then the perfect matching is unique. On the contrary, several perfect matching exist, which will result in the different causal interpretations around the loops. In the previous example, considering e_1 , V_1 and V_2 as exogenous variables, thus e_1 matches V_3 or V_6 . Considering e_2 , V_5 is a pseudo-exogenous variable, thus e_2 matches V_3 or V_4 . Considering e_3 , e_3 matches V_4 or V_6 .

Consequently, two solutions are available. If e_1 is matched to V_6 , then e_3 is matched to V_4 and e_2 to V_3 . If e_1 is matched to V_3 then e_2 is matched to V_4 and e_3 to V_6 . If e_1 is matched to V_6 and e_2 to V_4 then no perfect matching can be found. Figure 1-d is an example of perfect matching. The Ford and Fulkerson algorithm can be used to determine the perfect matching (Ford and Felkursion, 1956).

A directed graph \mathbf{G}' is derived from the perfect matching in \mathbf{G} . The edges belonging to the perfect matching are directed from \mathbf{E} to \mathbf{V} . The other edges are directed from \mathbf{V} to \mathbf{E} (Figure 1-e).

The causal graph $G_c = (V, I)$ is derived from the directed graph G' by aggregating the matched nodes. The causal graph that corresponds to Figure 1-e is shown in Figure 2 case n°1. Other admissible causal graphs are given in Figure 2, cases 2 to 7 (depending on the choice of pseudo-exogenous variables).




Figure 2: Causal graph possibilities. Different cases depending on the choice of exogenous variables

1.1.3 Suppression of unmeasured variables

It often happens that it is impossible to quantify each influence of the causal graph. In such cases, the only solution is to resort to identification methods to determine the differential or difference relationship, which is only possible if data are available for the variables. But the causal model structure contains *known variables* (measured variables, controller set-points, etc.) as well as *unknown variables*. This is why a *reduction operation* is used. It consists of eliminating unknown variables, keeping influence of physical components. It provides the *reduced causal model* (Heim, 2003). This procedure is similar to elimination theory (Staroswiecki et al., 1997).

1.1.4 Suppression of negligible variables

There may have some physical phenomena represented by influence relations that are negligible with respect to others, given the model objectives. The *approximation operation* accounts for such situations and results in an *approximated causal model* that contains only known process variables connected by quantified relations (Heim, 2003). These relations are transfer functions of first or second order in the FCC case.

1.1.5 Simulation of the model

For simulation purposes, the process is assumed linear around one steady state. For example (cf. Figure 3), let:

Y be an endogenous variable

U_i be variables which influence Y.

F_j be the transfer function between U_j and Y.




Figure 3: Transfer functions associated with a causal graph

The value of Y is described with the discrete transfer functions F_j :

$$F_j(z) = \frac{B_j(z)}{A(z)}, j = 1..n$$

From this equation, a difference equation is easily deduced, with Y^0 : value of Y in the steady state and q^{-1} : the shift operator:

$$A(q^{-1})Y(t) = Y^0 + \sum_{j=1..n} F_j(q^{-1}).U_j(t)$$

This quantitative causal graph can then be used as a simulator around the steady state.

1.2 Example of industrial application

This methodology is applied on the sub-system illustrated by Figure 4. It is the stripper and the regulated valve of the catalyst of an FCC. The aim of the valve is to regulate the catalyst level in the stripper.

This system has only one configuration in normal behaviour.




Figure 4: Example: Subsection of the FCC pilot plant

The variables used to describe the Stripper are found in Table 1.

Variable	Meaning	Unit	Sensor
----------	---------	------	--------

M_cata_stripper	Catalyst mass in the stripper	kg	-
P_fond_stripper	Pressure in the bottom of the stripper	Pa	-
P_stripper	Sky pressure in the stripper	Pa	PT20
Qe_cata_stripper	Mass catalyst flow in the input of the stripper	kg/s	-
Qs_cata_stripper	Mass catalyst flow in the output of the stripper	kg/s	-
L_cata_stripper	Catalyst level in the stripper	m	LT20
ρ_{cata}	Catalyst density	kg/m ³	

Table 1 : Variables describing the stripper

The variables used to describe the valve are found in Table 2.

Variable	Meaning	Unit	Sensor
DP_vanne_cata	Pressure drop in the valve	Pa	DPT24
LV_vanne_cata	Aperture of the valve	%	LV20
P_fond_stripper	Pressure in the bottom of the stripper	Pa	-
P_reg1	Sky pressure in the first regenerator	Pa	PT30
Qe_cata_vanne	Mass catalyst flow in the input of the valve	kg/s	-
Qs_cata_vanne	Mass catalyst flow in the output of the valve	kg/s	-
Cons_L_stripper	Set point of the level of the stripper	M	LT20

Table 2: Variables describing the valve

The following equations describe both systems.

$$a1: \Delta P_{stripper} = P_{stripper} - P_{fond_stripper}$$

$$a2: L_{cata_stripper} = M_{cata_stripper} * \frac{S_{stripper}}{\rho_{cata}}$$

$$a3: \Delta P_{stripper} = \rho_{cata} * g * L_{cata_stripper}$$

$$a4: Q_{S_cata_stripper} = Q_{E_cata_stripper} + \frac{dM_{cata_stripper}}{dt}$$

$$a5: Q_{E_cata_vane} = Q_{S_cata_stripper}$$

$$a6: Q_{S_cata_vane} = f_3(LV_{vanne}) * \sqrt{DP_{vanne_cata}}$$

$$a7: Q_{S_cata_vane} = Q_{E_cata_vane}$$

$$a8: \Delta P_{vanne_cata} = P_{fond_stripper} - P_{reg1}$$

$$a9: LV_{vanne_cata} = F_4(Cons_{L_stripper} - L_{cata_stripper})$$

with:

- $S_{stripper}$: section in the stripper
- f_3 : non linear function
- F_4 : transfer function

The following physical components are associated to each equations.

Equation	Components
a1	Stripper pressure sensor: PT20
a2	Stripper level sensor: LT20
a3	Stripper level sensor: LT20
a4	Stripper
a5	Stripper, valve
a6	valve, pressure drop sensor in the valve: DPT24

a7	valve
a8	pressure drop sensor in the valve: DPT24, pressure sensor in the stripper: PT30
a9	Controller of the valve

Table 3: Association of physical components to each equation

The causal graph in Figure 5 is obtained (variables in a rectangle (for example Qe_cata_stripper) are exogenous variables, variables in an ellipse (for example DP_stripper) are endogenous variables, measured variables (for example L_cata_stripper) are in bold, non measured variables (for example DP_stripper) are in white):




Figure 5 : Causal graph obtained for the system presented in Figure 4

Non measured variables are then suppressed (cf. 1.1.3) except exogenous variables. The causal graph in Figure 6 is then obtained :




Figure 6: Causal graph without non measured variables

The following components are associated to each influence:

- $\{Qe_cata_stripper \rightarrow L_cata_stripper\} = \{Stripper, Stripper\ level\ sensor: LT20\}$
- $\{Cons_L_stripper \rightarrow LV_vanne_cata\} = \{Controller\ of\ the\ valve\}$

- $\{L_cata_stripper \rightarrow LV_vanne_cata\} = \{\text{Controller of the valve}\}$
- $\{L_cata_stripper \rightarrow DP_vanne_cata\} = \{\text{Stripper level sensor: LT20, Stripper pressure sensor: PT20, pressure drop sensor in the valve: DPT24, pressure sensor in the stripper: PT30}\}$
- $\{P_reg1 \rightarrow DP_vanne_cata\} = \{\text{pressure drop sensor in the valve: DPT24, pressure sensor in the stripper: PT30}\}$
- $\{P_stripper \rightarrow DP_vanne_cata\} = \{\text{Stripper pressure sensor: PT20, pressure drop sensor in the valve: DPT24, pressure sensor in the stripper: PT30}\}$
- $\{LV_vanne_cata \rightarrow Qs_cata_stripper\} = \{\text{valve, pressure drop sensor in the valve: DPT24, Stripper}\}$
- $\{DP_vanne_cata \rightarrow Qs_cata_stripper\} = \{\text{valve, pressure drop sensor in the valve: DPT24, Stripper}\}$
- $\{Qs_cata_stripper \rightarrow L_cata_stripper\} = \{\text{Stripper, Stripper level sensor: LT20}\}$

1.3 Practical issues

The causal ordering algorithm needs choices to be made by an expert:

- some endogenous variables have to be considered as pseudo-exogenous (in the case where the number of equations is less than the number of endogenous variables);
- if there are algebraic loops, a choice has to be made referring to the causal interpretation around the loops.

The presence of pseudo-exogenous variables is due to the lack of formal relations for describing the process. This means that the causality driven simulation is guided by the measurements of these variables, which cannot be computed otherwise. Thus a first constraint is that pseudo-exogenous variables are measured variables. Further, in practice, the choice of a pseudo-exogenous variables is guided by:

- The different time scale dynamics of the variables. As we cannot detect fault on these variables, for safety reasons, it is better to chose variables with slow dynamics.
- The confidence in each sensor. It is better to chose pseudo-exogenous variables with robust sensor. If pseudo-exogenous error measures are very high, each threshold on father nodes will be high. The detection method will then be less sensitive.
- The choice of the pseudo-exogenous variables may influence the presence or the absence of loops in the quantitative causal graph. In our methods, loops (system of n algebraic equations with n measured variables without delays) are redhibitory for causal simulation, so are loops with less than two measured variables for local causal simulation². Pseudo-exogenous variables can be used to avoid such situations.

In the application to a FCC pilot plant, the choices were made using the two first guidelines (variables with slow time dynamics and sensitivity of each relation). The influence of the pseudo exogenous choices to the presence or not of loops or more generally to the sensitivity of the fault detection method is not studied yet.

2. Diagnostic methodology

This section presents a method for managing residuals based on the causal graph generated in the previous step.

First *the detection module* (section 2.1) generates alarms. The causal graph provides references characterising the normal behaviour of the process. Comparing measures with these references, the fault detection module determines whether measured variables have an abnormal behaviour or not (analytical redundancy), and generates alarms.

² When a loop includes two measured variables, the measured value of one can be used to predict the value of the other.

For each variable, the fault detection module generates *two references* considering a local environment and a global one (given by exogenous variables). This is important for detection of incipient faults and for safety which absolutely requires to check critical variables in regards to their set points.

Additionally, each influence of the causal model is associated with a set of physical components. **The isolation module** (section 2.2) applies a hitting set algorithm on the list of components associated to edges connected to variables which have an abnormal behaviour. This allows determining a subset of physical components that behave abnormally, the diagnoses.

Finally, **the fault identification module** (section 2.3) generates more information and provides a final message to the operator. Each component is associated with semi-qualitative models of its abnormal behaviour. These models are obtained from the operator expert knowledge and expressed in the form of a fault/symptom tree. When a component is suspected by the isolation module, its fault/symptom tree is activated. Symptoms are qualified by a signal analysis, faults and possible actions are identified and suggested to the operators.

2.1 Fault detection

The aim of this module is to determine if the state of each variable is correct or not. Let $y_i(t)$ represent the measured value of each node of the causal graph. The causal model provides a global reference $y_i(t)^*$ and a local one $\hat{y}_i(t)$. Thanks to these values, two residuals are defined.

$$\rho(t) = y_i(t) - y_i(t)^* = \varepsilon_i : \text{global residual}$$

$$\lambda(t) = y_i(t) - \hat{y}_i(t) = \varepsilon_i^p : \text{local residual}$$

The causal diagnostic methodology consists in deciding for each node if the fault is local (and thus explains all the other observed discrepancies) or if the fault is upstream (and thus explained by the fault on another variable).

2.1.1 Global residual

A global residual is the difference between measures and references calculated from the global reference of father nodes. It indicates the consistency of a measure regarding exogenous variables. Let Y be a variable and U_j the variables which influence Y (cf. Figure 3). The global reference of Y is calculated by:

$$Y^{global} = Y^0 + f(\dots, U_j^{global}, \dots) \text{ (where } U_j^{global} \text{ stand for the global reference of } U_j)$$

This global reference is computed from exogenous variables acting on the process (nominal value). The simulator outputs are compared with the process sensor outputs. The global residual alone allows only detection: it is clear that ε_i is excited either by a local discrepancy or by a discrepancy in an upstream variable U_j . Using this residual, it is then not possible to isolate the fault (Montmain and Gentil 2000).

2.1.2 Local residual

A local residual is the difference between measures and references calculated from the measures of father nodes (using the same transfer function as global residual). It indicates the coherency of the measure regarding a local environment. The local reference is calculated by:

$$Y^{local} = Y^0 + f(\dots, U_j^{mes}, \dots) \text{ (where } U_j^{mes} \text{ stand for the measure of } U_j)$$

In this equation, the simulated evaluation of U_j has been replaced by its measured evolution to obtain the predicted evolution. The predicted value represents the value computed from the measured values of the antecedent nodes. As U_j^m stands for the measure of U_j , this residual is only affected by the fault on the components related to the entering arcs in Y or to Y and U_j sensors. It enables local reasoning (i.e. cutting the influence of propagated faults). It enables to focus on relations that have been shown to be sufficient to allow fault isolation (Gentil et al., 2004). This avoids the combinatorial explosion that could be feared when dealing with industrial plants.

2.1.3 Alarm generation

The results of the Boolean reasoning on the residuals (global and local ones) are shown in Table 4. The number 1 symbolises that the value of the residual is greater than a threshold and 0 that the residual is smaller than this threshold.

$\lambda_i(t)$	$\rho_i(t)$	Fault
1	0	Local
0	1	Upstream

Table 4: Boolean reasoning on residuals

Table 4 could be used for process diagnosis, but using Boolean reasoning implies choosing very carefully the thresholds. Moreover, in case of a drift fault, there is a delay between the fault appearance and its detection. The operator is informed of the fault after its value is higher than the threshold. A way to cope with this problem is to use a fuzzy reasoning approach. The fuzzy approach described in this paper uses inferences extracted from Table 4 to analyse the residuals. Moreover, the residual variations are used in order to take into account residual tendencies. In order to take into account the measurement noise, memberships of past residuals and their variations to respective labels are computed (Evsukoff et al. 2000).

Five fuzzy sets are used to describe the residual values (Figure 7). The linguistic labels of these sets are the usual ones: negative high NN, negative medium N, zero Z, positive medium P, positive high PP.

Three fuzzy sets (N^* , Z^* and P^*) are used to describe the variation of residual (Figure 8).




Figure 7: Fuzzy partition of residuals




Figure 8: Fuzzy partition of variation of residuals

The fuzzy sets form 15 combinations (Table 5). The linguistic label OK means that the situation is normal and AL that the situation is abnormal (alarm). Symbolic fuzzy sets are used to express the meaning of these labels. μ/label expresses a membership of value μ to the label. Obviously AL and OK are complementary. For instance, if the residual is positive medium with a negative variation, this means that it is decreasing, so the situation is not so bad (0.6/OK). On the other hand, for positive variations, the situation is bad and worsening (1.0/AL). A similar table is based on $\lambda(t)$ in order to isolate the faults, with a symbolic reasoning concluding that the fault is local to a variable (LO) or upstream (UP) in the graph. For instance, if the residual $\lambda(t)$ is medium positive with a positive variation, this means that it is increasing, there is a local fault that is increasing (0.8/LO) and (0.2/UP).

		derivative		
		N^*	Z^*	P^*
residual	NN	0/OK 1/AL	0/OK 1/AL	0.2/OK 0.8/AL
	N	0/OK 1/AL	0.4/OK 0.6/AL	0.6/OK 0.4/AL
	Z	0.8/OK	1/OK	0.8/OK

	0.2 AL	0/AL	0.2 AL
P	0.6/OK 0.4/AL	0.4/OK 0.6/AL	0/OK 1/AL
PP	0.2/OK 0.8/AL	0/OK 1/AL	0/OK 1/AL

Table 5: Detection decision table for ρ

		derivative		
		N*	Z*	P*
residual	NN	0/UP 1/LO	0/UP 1/LO	0.2/UP 0.8/LO
	N	0/UP 1/LO	0.4/UP 0.6/LO	0.6/UP 0.4/LO
	Z	0.8/UP 0.2/LO	1/UP 0/LO	0.8/UP 0.2/LO
	P	0.6/UP 0.4/LO	0.4/UP 0.6/LO	0/UP 1/LO
	PP	0.2/UP 0.8/LO	0/UP 1/LO	0/UP 1/LO

Table 6: Detection decision table for λ

Fuzzy reasoning provides three membership functions between 0 and 1. The first function informs about the state of the variable, OK/AL. The gradual evolution between 0 and 1 characterises the evolution of the variable from a normal state to an undesirable one (detection). This transition is used in the supervision interface representing the causal graph for the operators- in terms of a colour code. The value that characterises the state of the variable is used to colour the contour of the nodes. The contour of the node is red when a fault is surely detected ($\mu/AL=1$) and green when not ($\mu/OK=1$). In between, it evolves through yellow, orange...

The average value of the two other membership functions informing on the localisation of the fault (LO/UP) is used to colour the arcs of the graph. The input arrows are green for a surely local fault and red for a surely upstream one.

The use of transition colours shows that fuzzy logic is useful to follow the variable gradual evolutions. Moreover this approach is close to human thinking and is well adapted to real processes with model uncertainties and measurement imprecision.

2.1.4 Application to the FCC pilot plant

In the FCC application, the model that is used contains 29 components, 40 variables and 25 causal relations. It was derived from a larger model containing 323 variables and 282 causal relations following the methodology presented in section 1.

The causal graph can be displayed on the operator interface and used as a visual tool for fault detection and isolation on variables as well as for explanation. A node is green when no discrepancy is detected (for example, pc30 in Figure 9) and red when a discrepancy is detected (for example PT20), arcs influencing a variable are red for a local fault (for example between PT20 and PC20) and green otherwise (for example between PC30 and PT30)(cf. Figure 9 where red arcs appear in bold and red nodes in grey circles).

Figure 9 presents the causal graph which is used for development purposes. Figure 10: presents the alarms and synoptic which are given to operators.




Figure 9: Example of the causal graph used in development




Figure 10: Visualisation of alarms in the FCC synoptic

2.2 Fault isolation on physical components

Having detected a discrepancy between predictions and observations, the aim of the isolation process is to search for the original possible cause(s) and to elaborate of a list of potential diagnoses. A diagnosis is a minimal set of components for which the invalidation of the normal behaviour assumptions yields (SD, COMP, OBS) consistent, where

- SD is a formal description of the system including assumptions of normal behaviour for the set COMP.

- COMP: set of components.
- OBS: set of observations.

In the proposed approach, the causal graph acts as the SD and the influences attached to the edges are the elements of COMP.

The diagnostic process is initiated as soon as a variable is isolated as being the source of the detected misbehaviour (deduced from the local residual). For this variable (i.e. a node in the causal graph), conflict generation procedure traces the causal graph, following the intuition that the influences which may be at the origin of the misbehaviour of variable X are those related to the edges entering into X (and only those ones).

The diagnostic generation is based on generating the minimal hitting sets of the collection of conflicts generated by the above algorithm (Cordier et al. 2000) (a set S that has a non-empty intersection with every set in a collection of sets C is called a hitting set of C; if no element can be removed from S without violating the hitting set property, S is considered to be minimal). A diagnosis is hence a set of components such that its intersection with each conflict set is not empty.

Different hypotheses referring to exoneration assumptions may be considered (Travé-Massuyès et al. 2001). Exoneration implies that a fault always manifests itself, which depends on the existence or absence of compensatory effects within the system as well as on the sensitivity of the fault detector. In the FCC application, practical considerations led us to assess that the exoneration assumption is valid for sensors. We assess that sensors are reliable components, i.e the sensors associated with the arcs directly influencing a non-misbehaving variable are considered to be normal.

Figure 11 is an example of a list of components of the FCC pilot plant associated to a colour code. The following abbreviations are used:

- C: Component;
- $\cup C$: Union of conflicts;
- $\cap C$: Intersection of conflicts;
- FAM: Fault always manifested;
- AWF: Arc without faults.

Table 5 gives the algorithm computing the colour code.

a)	Initially all the components are represented by a green square
b)	IF $C \in \cup C$ THEN "external part of square" = red
c)	If FAM=True for the current component C IF $C \notin \cap C$ THEN "internal part of square" = green IF $C \in \cap C$ and $C \notin AWF$ THEN "internal part of square" = red
d)	If FAM=False IF $C \in \cap C$ THEN "internal part of square" = red
e)	(Multiples faults) IF $C \notin \cap C$ AND $C \in \cup C$ THEN "internal part of square" = orange

Table 7: Colour code displayed in the squares in Figure 11

The square colour ranges from red for incriminated single fault components to green for non incriminated components, and can be orange when the component can take part in a multiple fault.



Figure 11: Visualisation of faulty and non-faulty components

2.3 Fault identification

Having estimated the list of physical components which have an abnormal behaviour, the aim of fault identification is to generate a message in natural language describing the particular fault on a suspected component to the operator.

To complete this task, each physical component is associated with semi quantitative models of its abnormal behaviour. These models (Heim et al. 2001), obtained from human operator knowledge (Hazop analysis), take the form of AND/OR fault/symptom tree (cf. Figure 12). They are activated only when the component is suspected to have an abnormal behaviour.




Figure 12: Semi/Quantitative abnormal model structure

Symptoms take the form of signal analysis: increases \uparrow , decreases \downarrow , pulse \uparrow & \downarrow , oscillation \updownarrow , steps \updownarrow .

When there exists negligible and complicated phenomena that are not modelled with the causal model, the abnormal behaviour model allows refining the diagnosis concerning those phenomena. It gives also a list of actions in order to verify and to counteract the fault.

Figure 13 is an example of an expert graph obtained for the stripper. It indicates that if the pressure stripper is low and the valve opening that regulates the pressure is 0%, then there is a leakage between the riser and stripper. In order to confirm this diagnosis, the operator has to verify that the pressure set-point is different from the measure. The repercussions are then defined. They depend on the type of regulation used (cascade 1 or 2).




Figure 13: Riser expert graph

3. Implementation

This approach was implemented using Gensym's G2 software. G2 allows object oriented and graphical programming of real time application. Causal graph nodes and directed arcs are represented by objects. Causal graph can easily be modified adding a node and connecting it with other nodes. Selecting any arc enables to change its transfer function parameters, and to modify its associated components list. In the fault/symptom tree associated to each physical component, symptoms and messages delivered to the operator are represented by objects. Relationships between symptoms and faults are symbolised by directed arcs. Parameters can be changed (variable identity, amplitude, frequency...) to change the sensitivity of the signal analysis. This allows to tune an application and to apply it to different processes or sites.

4. FCC application

4.1 FCC process

FCC process includes many subsystems (two regenerators, a reactor, a separation column, pipes, valves...). The reactor riser temperature is very close to the metallurgical limits for optimum production. As a result of cracking, carbonaceous products (called coke) get deposited on the catalyst, which decreases the effectiveness and the lifetime of the expensive catalyst. This one is continuously regenerated in the regenerator by blowing in air. Coke is combusted to CO, CO₂, and H₂O. The amount of CO vented out through the stack gas is very crucial from an environment point of view, and one of the challenges for our application is not to violate the environmental threshold and to achieve an optimum performance in the face of disturbances. There is a constant flow of regenerated and spent catalyst between the reactor and the regenerator. This flow is partly driven by the pressure differential between the reactor and regenerator, and the remaining momentum is supplied by the lift air blower. The fractionator's section separates the product hydrocarbons for further processing. A feed system consisting of low-level flow controllers and a preheating furnace pre-processes the feed for cracking.

The FCC chosen is a pilot plant. Table 6 describes order of magnitudes of the physical variables in a real FCC and in a FCC pilot plant:

Characteristics	Industrial FCC	FCC pilot plant
Capacity	40000 barrels/day	2 barrels/day
Regenerator long	15 m	1 m
Regenerator diameter	8 m	20 cm
Riser long	35 m	7 m

Riser diameter	1 m	2 cm
Feed flow	245 t/h	6 kg/h
Catalyst flow	1500 t/h	40 kg/h
Total mass of catalyst	300 tonnes	40 kg
Contact time in the riser	2 à 4 sec	1 sec
Contact time in the stripper	1 min	15 min
Contact time in each regenerator riser	5 min	20 min

Table 8: Differences between an industrial FCC and the FCC pilot plant

In the FCC pilot plant (Figure 14), the catalyst circulates in a physical closed loop: it goes from the stripper (*R3*), to the 1st regenerator (*R1*) then to the 2nd regenerator (*R2*) then to the riser (*R1*) and finally comes back to the stripper (*R3*). Catalyst circulation is ensured by pipes: the lift (*T2*), the stand pipe (*T3*) and the riser (*T1*). Riser is also a reaction zone. The feed is put in contact (via *V6*) with the catalyst in the riser during few seconds and immediately catalyst and reaction products fall in the stripper. The stripper *R3* separates valuable components and low boiling point molecules from the catalyst and the coke. Coke is a reaction secondary product composed of high boiling point molecules. Valuable components are separated from low boiling point molecules by a separation column (*C1*). A filter (*F1*) between the column and the stripper prevents catalyst from going in the separation column. The catalyst and the coke are driven to the first regenerator *R1* through a valve *V4*. Coke is partially burnt in the first regenerator. The second regenerator *R2* finishes this combustion. At the output of the second regenerator, the hot regenerated catalyst that is driven to the bottom of the riser rapidly reacts with the feed. Three pressure control valves *V1*, *V2*, *V3* are used to control respectively the stripper, 1st regenerator and 2nd regenerator pressures. Nitrogen flows are controlled to ensure the catalyst circulation (*V7* to *V12*). Air flows are controlled to ensure the coke combustion (*V13* and *V14*). Catalyst levels in stripper and separation column are controlled respectively by valves *V4* and *V5*. Filters *F2* and *F3* respectively prevent catalyst from going into *V2* and *V3*

Problems that occur in a industrial FCC are (Sadeghbeigi, 2000) :

- Catalyst circulation
- Catalyst loss
- Coking/Fouling
- Flow reversal
- High regenerator Temperature
- Afterburn
- Hydrogen Blistering
- Hot Gas Expander
- Products Quality and Quantity

Problems that occur on the FCC pilot process have been classified in 6 types:

- Blockage (pipe, valve, ... , cf. scenario 1),
- Leakage,
- Change in the material properties (catalyst, ...).
- Bad operation (operator, ... , cf. scenario 2),
- Sensor faults (cf. scenario 3),
- Utilities (gas, electricity, ..., cf. scenario 4),




Figure 14: FCC pilot plant process variables

4.2 Scenarios description

This paragraph presents scenarios that happened on the FCC pilot plant.

In the application, the assumption is made that a sensor fault always manifests (cf. 2.2). Therefore, in the following sections, sensors are exonerable components.

Table 7 presents the detection time obtained using the presented method, named ASCO, with the one an operator would obtain (ASCO stands for : "Aide à la Supervision et à la Conduite pour les Opérateurs"). These times are suggestive, and are obtained from historical data.

- Column 1 describes the type of fault
- Column 2 describes the failure
- Column 3 gives the detection time for ASCO
- Column 4 gives the detection time for an operator

Faults	Description	Time for detection	
		ASCO	Operator
Blockage	1. Blockage of pipes between stripper and column	5 minutes	50 minutes
	2. Blockage of valve on the first regenerator	5 minutes	15 minutes
	8. Gas bubbles in the pump circuit	20 minutes	1 hour
	5. Filters in the first regenerator	1 minute	15 minutes
	6. Filters in the second regenerator blocked	1 minute	15 minutes
	Sensor faults	3. Abnormal level in the first regenerator	1 minute
Operator faults	4. Bad operator actions creating disturbances in the process	1 minute	5 minutes
	8. Gas bubbles in the pump circuit	1 minute	10 minutes
	11. Gas present between the first and second regenerator	5 minutes	10 minutes
Utilities	7. Lack of air to operates the regulation valves in two regenerators	5 minutes	Not detected
Process	9. Stand pipe drain	1 minute	10 minutes
	10. Catalyst present between the stripper and the separation-column	55 minutes	1 hour
Wear	12. Abnormal behaviour of level regulation valve in the stripper	55 minutes	20 minutes

Table 9: Time detection in practical scenarios

The following sections present four scenarios of abnormal situation.

4.2.1 Scenario #1

This scenario corresponds to a blockage between stripper (R3) and separation column (C1). Catalyst is carried in this line by gas flow from Stripper (R3) toward the separation column (C1). Figure 15 shows influences provided by the causal graph in this scenario (without sensors). For example, RV3 component (controller of valve V3) is in the support (list of physical components) of influences SPS->OPPS and OPPS->PS.

Faults are detected on variables PS (R3 pressure), OPPS (V1 opening value), DPR (Riser pressure drop), DPL (lift pressure drop), DPS (cocker pressure drop), FS (V1 effluent flow), LR2 (second regenerator level), LR1 (first regenerator level), PC (Separation column sky pressure), DPC (V4 pressure drop) and OPLS (V4 opening value). These variables are grey in Figure 16.

Faults are isolated on variables FS (V1 effluent flow) and PS (R3 pressure). Arcs influencing these variables appear in bold in Figure 16.




Figure 15: Influences and their underlying components




Figure 16: Causal graph in scenario 1

Figure 17 presents global and local residuals of Stripper (R3) pressure: $r_{PS}(t)$ (left), $\lambda_{PS}(t)$ (right). Figure 18 presents global and local residuals of V4 pressure drop: $r_{DPC}(t)$ (left) and $\lambda_{DPC}(t)$ (right). Thresholds a_{PS} and a_{DPC} are symbolised by horizontal lines.




Figure 17: $r_{PS}(t)$, $\lambda_{PS}(t)$ (variation of local and global residuals of PS)




Figure 18: $r_{DPC}(t)$ and $\lambda_{DPC}(t)$ (variation of local and global residuals of DPC)

A fault is detected on PS (R3 pressure) because $r_{PS}(t)$ is greater than a_{PS} for $t > T1$. This fault is local because $\lambda_{PS}(t)$ is greater than a_{PS} for $t > T2$. A fault is detected on DPC (V4 pressure drop) because $r_{DPC}(t)$ is greater than a_{DPC} for $t > T3$. But this fault is upstream because $\lambda_{PS}(t)$ is always inferior to a_{DPC} .

The set of components associated with the arcs influencing FS (V1 effluent flow) defines a conflict because $\lambda(FS) > 0$. This conflict is $\{C1, F1, V1, V5, FS_t, OPPS_t, PS_t\}$ where the notation Y_t refers to the component that transmits the value of Y . The set of components associated with the arcs influencing PS (R3 pressure) defines a conflict because $\lambda(PS) > 0$. This conflict is $\{C1, F1, R3, T1, V1, V5, OPPS_t, FNS_t, FFR_t, FNR_t, PS_t\}$.

Knowing these two conflicts, minimal diagnoses are $\{C1\}$, $\{F1\}$, $\{V1\}$, $\{V5\}$, $\{OPPS_t\}$, $\{PS_t\}$, $\{FS_t, R3\}$, $\{FS_t, T1\}$, $\{FS_t, FNS_t\}$, $\{FS_t, FFR_t\}$, and $\{FS_t, FNR_t\}$ (simple and multiple faults without exoneration). These sets of components intersect both conflicts. If we consider only simple faults, following diagnoses are obtained: $\{C1\}$, $\{F1\}$, $\{V1\}$, $\{V5\}$, $\{OPPS_t\}$, $\{PS_t\}$.

Sensors are considered as exonerable components. Therefore when the local residual of a variable is lower than its threshold, sensors measuring upstream variables are removed from diagnoses. In this scenario, the local residual of LR2 (second regenerator level) is lower than a_{LR2} . Consequently, sensor PS_t that is associated with this residual is removed from diagnoses.

Sensor $OPPS_t$ (V1 opening value) is also considered not faulty because its local residual is also lower than a_{OPPS} . Therefore, sensor minimal diagnosis is \emptyset , thus, no single sensor fault is suspected.

Following diagnoses are then obtained : $\{F1\}$, $\{C1\}$, $\{V1\}$, $\{V5\}$. Fault/symptom tree of F1, C1, V1 and V5 are activated. The signal analysis generates two symptoms: PS (R3 pressure) \nwarrow , $OPPS$ (V1 opening value) \nwarrow . A qualitative expert rule (cf. Figure 19) is launched and the following message is delivered to the operator: "Fault: Blockage of V1 or C1. Confirmation: By pass C1. If pressure PS (R3 pressure) decreases then C1 abnormal else V1 abnormal."




Figure 19: Expert graph activated for scenario #1

V1, F1, C1 and V5 fault/symptom trees are made of several other rules but no other combination of symptoms is observed. Therefore, no other conclusion can be considered.

Without any diagnostic module, operators may not detect the fault before security systems automatically halt the process, after 40 minutes. With the diagnostic module, the fault is isolated 5 minutes after its inception, allowing 35 minutes for operators to act on the process.

V1 is composed of two parallel valves V1a and V1b. If only one valve (V1a for instance) is blocked then operation can be maintained controlling PS (R3 pressure) only with V1b. The operator has time to change V1a.

4.2.2 Scenario #2

This scenario corresponds to the formation of bubble of gas in the feeding pump because the valve V6 temperature, T_{V6} , is too high. The variables directly affected are FFR (V6 feed flow) and OPFFR (V6 opening value). Faults are detected on {OPFFR, FFR, PS, OPFS, FS, DPS, PC, DPR, DPL, LR2, LR1}. Faults are isolated on {FFR, OPFFR}. Components associated with the arcs influencing FFR (V6 feed flow) define a conflict. This conflict is {V6, RV6, FNT, OPFFR_t, FFR_t}. Components associated with the arcs influencing OPFFR (V6 opening value) define a conflict. This conflict is {V6, RV6, FNT, OPFFR_t}. Minimal diagnoses are {V6}, {RV6}, {FNT} and {OPFFR_t}.

The operator is informed that sensor OPFFR_t is suspected to be faulty. In fact this sensor is not faulty. Having more knowledge on sensors will enable to exonerate this sensor. Fault symptom trees of V6, RV6 and FNT are activated. The qualitative model associated with SC2 fault is given by.

$[(F1 \uparrow \rightarrow) \text{ or } (F1 \downarrow \rightarrow)] \text{ and } [T_{V6} >]$

$(F1 \uparrow \rightarrow)$ and $T_{V6} >$ are observed making signal analysis. The qualitative rule $(F1 \uparrow \rightarrow)$ and $(T_{V6} >)$ is observed therefore this message is delivered:

Message 2 : "Gas bubbles in the feeding pump V6. Stop feeding and wait until TV6 decreases".

Temperature T_{V6} is a variable that has not been introduced in the model but that is interpreted in the fault identification module.

In this scenario, the only delivered message is Mess2.

The time of abnormal behaviour occurrence is 50 minutes. 10 minutes are necessary to the operator to isolate the fault without the diagnostic module. The diagnostic module instantaneously generates the message.

The operator has to stop feeding and to wait until T_{V6} decreases. Feed can then be reactivated. If the operator does not react rapidly enough the FCC pilot can go into a not permitted state that activates automatically security monitoring functions.

4.2.3 Scenario #3

This scenario corresponds to a fault on sensor LR1 (first regenerator level). The variable which is directly affected is LR1. A fault is detected and isolated on LR1. Components associated with the arcs influencing LR1 are {T1, T2, T3, T4, R1, R2, R3, V4, LR1_t, LR2_t, LS_t}. Therefore, conflicts are {T1}, {T2}, {T3}, {T4}, {R1}, {R2}, {R3}, {V4}, {LR1_t}, {LR2_t} and {LS_t}.

Sensor LR2_t (second regenerator level) is not faulty because $\lambda(\text{LR2})=0$. Sensor LS_t is not faulty because $\lambda(\text{LS})=0$. The operator is informed that sensor LR1_t (first regenerator level) is suspected.

Fault symptom tree of T1, T2, T3, T4, R1, R2, R3 and V4 are activated. The identification module does not deliver any message because the FCC behaves normally.

The time of abnormal behaviour occurrence is approximately 40 minutes. 5 minutes are necessary for the operator to isolate the fault without the diagnostic module. Fault isolation is instantaneous with the diagnostic module. LR1 sensor (first regenerator level) is blocked with catalyst. The operator has to create a gas stream inside the sensor to repair it.

4.2.4 Scenario #4

This scenario corresponds to a decrease of the air network pressure. The variables directly affected are OPFOR1 and OPFOR2. This network pressure is not transmitted to the diagnostic module. Faults are compensated by control loops (RV13 and RV14) and do not propagate in the causal graph. Faults are detected and isolated on OPFOR1 and OPFOR2.

Conflicts are {RV13, V13, ONT, OPFOR1,} because $\lambda(\text{OPFOR1}) > 0$ and {RV14, V14, ONT, OPFOR2,} because $\lambda(\text{OPFOR2}) > 0$. A minimal diagnosis is {ONT}, so, ONT fault symptom tree is activated. Symptoms (OPPR1 <) and (OPPR2<) are observed. Therefore, the following message is delivered to the operator: "Decrease of the air pressure network. Check if this measure is low.". Symptom/trees associated to other diagnosis do not provide any other conclusion.

The qualitative model associated with SC4 fault is

$$[(\text{OPPR1} \downarrow) \text{ or } (\text{OPPR1} <)] \text{ or } [(\text{OPPR2} \downarrow) \text{ and } (\text{OPPR2} <)]$$

(OPPR1 <) and (OPPR2<) are observed, therefore, the following message is therefore delivered to the operator:

Mess4: "Decrease the air pressure network. Check if this measure is low."

In this scenario, the only delivered message is Mess4.

The time of abnormal behaviour occurrence is approximately 15 minutes. This fault was not detected by the operator because the gas flows were maintained at their set point. The diagnostic module generates the message 3 minutes after the fault occurrence. Thanks to this information, the operator can engage actions on the air pressure network before its pressure is too low.

5. Conclusion

This paper presents a methodology to apply a diagnostic method to an industrial size process. The combination of complementary techniques (modelling, fault detection, fault isolation and fault identification) is used.

Modelling is carried out using a causal model which describes the normal influences among process variables and supports qualitative and quantitative information. The initial knowledge consists in the process variables (endogenous and exogenous variables), and the set of formal relations, related to physical components, that describe the variables. This knowledge constitutes the structural relation model. The application of a causal ordering algorithm to the structural relation model provides the causal graph, which exhibits the causality underlying the set of relations in the form of a set of directed influences between variables. Other operations are

further necessary, due to the practical difficulty in quantifying the relations involved in the causal graph with theoretical knowledge. Model identification and parameter estimation is generally used, which is only possible if data are available for the variables. A *reduction operation* consists in eliminating unknown variables from the graph. An *approximation operation* results in an approximated causal model that contains only known process variables connected by quantified relations. At this step the model is ready for causal simulation which is to say for computing the endogenous variables from the measured values of the exogenous ones. As the influences are associated to specific physical components, the approximated causal model is also suitable for supporting diagnosis, i.e. fault isolation.

Fault detection is carried out using classical analytical redundancy. The quantitative causal model provides references characterising the normal behaviour of the process. Comparing measures with these references, the fault detection module determines whether measured variables have an abnormal behaviour or not, and generates alarms. For each variable, the fault detection module generates *two references* considering a local environment and a global one (given by process set points and measured external disturbances). This is important for detection of incipient faults and for safety which absolutely requires checking critical variables in regards to their set points.

Isolation is carried out applying a hitting set algorithm on the list of components associated to edges connected to variables which have an abnormal behaviour. This allows determining a subset of physical components, the diagnoses, that behave abnormally.

Identification is carried out generating more information and provides a final message to the operator. Each component is associated with semi-qualitative models of its abnormal behaviour obtained from the operator expert knowledge and expressed in the form of a fault/symptom tree. When a component is suspected by the isolation module, its fault/symptom tree is activated, symptoms are qualified by a signal analysis, faults and possible actions are identified and suggested to the operators.

The methodology presented in the paper has been proven feasible on a FCC pilot plant. A FCC plays a key role in an integrated refinery as the primary conversion process. For this process, reliability is required to allow long-term operation between maintenance shutdowns (every 3-5 years typically). The faults to be detected on the FCC pilot plant are leakages (on pipes, tanks, valves...), blockages (on pipes, actuators, injections...), abnormal process behaviour (wrong PID parameters, abnormal gas bubbles inside the process, empty tanks...), problems on sensors, regulators, and external services (such as electricity, gas network...). ASCO was tested off-line on 13 scenarios containing faults and succeeded in identifying the faults a long time before the operators (10 minutes to an hour) with robustness. For doing so, it uses a model containing 29 components, 40 variables and 25 directed relations that was derived from a model containing 323 variables and 282 directed relations. The software always isolates the faults much faster than the operator.

Acknowledgements

This work is conducted as part of the CHEM EC funding project: "Advanced Decision Support System for chemical and petrochemical processes" Project is funded by the European Community under the Competitive and Sustainable Growth programme of the Fifth RTD Framework Programme (1998-2002) under contract G1RD-CT-2001-00466. See www.cordis.lu or www.chem-dss.org

References

Blanke, M., Kinnaert, M., Lunze, J. and Staroswiecki, M. (2003) in *Diagnosis and Fault Tolerant Control*, Springer Verlag, (600 p.).

Cassar, J.P. and Staroswiecki, M. (1997) A structural approach for the design of failure detection and identification systems, *Proc. of the IFAC symposium on Control of Industrial Systems* Belfort.

Cauvin, S. and Celse, B. (2004) CHEM : Advanced Decision Support Systems for Chemical/Petrochemical process industries. *ESCAPE-14 Congress* Lisbonne.

Cauvin, S., Celse, B., Gentil, S. and Travé-Massuyès, L. (2004), Model based diagnosis module for a FCC pilot plant, *ERTC Congress* London.

- Cordier, M., Dague, P., Dumas, M., Levy, F., Montmain, J., Staroswiecki, M., and Travé-Massuyès, L. (2000). A comparative analysis of AI and control theory approaches to model-based diagnosis. *ECAI '00 Congress*.
- Dion, J-M., Commault, C., Van der Woude, J. (2003) Generic properties and control of linear structured systems: a survey, *Automatica*, **39**, 1125-1144.
- Evsukoff, A., Montmain, J., and Gentil, S. (1997) Dynamic model based supervising and causal knowledge-based fault detection and isolation. *IFAC Safeprocess '97 congress*, Hull, 699-704.
- Evsukoff, A., Gentil, S. and Montmain, J. (2000) Fuzzy Reasoning In Co-operative Supervision Systems, *Control Engineering Practice*, **8**, 389-407.
- Ford, L. R. Jr. and Fulkerson, D. R. (1956) Maximal flow through a network, *Can. J. Math.*, **8**, 399-404.
- Frank, P. (1990) Fault diagnosis in dynamic systems using analytical and knowledge-based redundancy, a survey and some new results, *Revue Européenne Diagnostic et Sûreté de fonctionnement*, Hermès, **26**, **3**, 459-474.
- Frank, P. (1991) Fault diagnosis in dynamic systems using software redundancy, *Revue Européenne Diagnostic et Sûreté de fonctionnement*, Hermès, **1**, **2**, 113-143.
- Frank, P. and Ding S. (2000) Current development in the theory of FDI, *IFAC Safeprocess* Budapest, 16-27.
- Gentil, S., Montmain, J., Combastel, C. (2004) Combining FDI and AI approaches within Causal-Model-based diagnosis, *IEEE Transactions SMC-Part B*, **34**, **5**, 2207-2221.
- Heim, B., Cauvin, S. and Gentil S. (2001) A fuzzy and causal reasoning methodology coupled with an heuristic approach for fault diagnosis on a FCC pilot process *4th Workshop on On-Line Fault Detection and Supervision in the Chemical Process Industries*, Seoul, 2001.
- Heim, B., Gentil, S., Cauvin, S., Travé-Massuyès, L., and Braunschweig, B. (2002) Fault diagnosis of a chemical process using causal uncertain model *15th European Conference on Artificial Intelligence*, Lyon, July 21-26 2002.
- Heim, B. (2003) Approche ensembliste et par logique floue pour le diagnostic causal de procédés de raffinage - Application à un pilote de FCC, PhD Thesis, INPG Grenoble.
- Isermann R. (1993) Fault diagnosis of machines via parameter estimation and knowledge processing - Tutorial paper, *Automatica*, **29**, **4**, 815-835.
- Isermann, R. and Ballé, P. (1997) Trends in the application of model-based fault detection and diagnosis of technical processes, *Control Engineering Practice*, **5**, **5**, 709-719.
- Iwasaki, S. and Simon, H. (1986), Causality in device behavior, *Artificial intelligence*, **29**, **1-3**, 3-32.
- Kramer, M.A and Palowitch Jr.B.L. (1987), A rule based approach to fault diagnosis using the signed directed graph, *AIChE Journal*, **33**, **7**, 1067-1078.
- Leyval, L., Gentil, S., Feray-Beaumont, S (1994) Model based causal reasoning for process supervision, *Automatica*, **30**, **8**, 1295-1306.
- Maurya, M.R., Rengaswamy and R., Venkatasubramanian, V., 2003, A systematic framework for the Development and Analysis of Signed Digraphs for Chemical Processes. A. Algorithm and Analysis, *Ind. Eng. Chem. Res.*, **42**, 4789-4810.
- Montmain, J. and Gentil, S. (2000) Dynamic causal model diagnostic reasoning for online technical process supervision, *Automatica*, **36**, 1137-1152.
- Murota, K., (1991), *Matrices and matroids for system analysis*, Ed. Springer (Algorithms and Combinatorics).

- Patton, R., Chen, J. (1991) A review of parity space approaches to fault diagnosis, *Safe Process 91, IFAC symposium on fault detection, supervision and safety for technical processes*, **1**, 239-255.
- Porté, N., Boucheron, S., Sallantin, S. and Arlabosse, F. (1988), An algorithmic view at causal ordering, *Proc. of the 2nd International Workshop on Qualitative Physics QR'88*, Paris, 1988.
- Rasmussen J., (1993), Diagnostic reasoning in action, *IEEE Trans. on Systems, Man and Cybernetics*, **23**, **4** , 981-991.
- Raider, and Mari Lyn (1996), Worldwide Refining, *Oil & Gas Journal*, **23**, 52.
- Reiter, T. (1987), A theory of diagnosis from first principles. *Artificial Intelligence*, **32**, 57-95.
- Sadeghbeigi R.(2000), Fluid catalytic cracking handbook, *Gulf Publishing company*.
- Staroswiecki M. and Comtet-Varga G. (2001) Analytical redundancy relations for fault detection and isolation in algebraic dynamic systems, *Automatica*, **3**, **5**, 697-699.
- Travé-Massuyès, L. and Pons, R. (1997) Causal ordering for multiple mode systems, *Proc. of the 11th Int. Workshop on "Qualitative Reasoning about Physical Systems"*, Cortona, 1997.
- Travé-Massuyès, L. and Gentil, S. (1999), Artificial intelligence approaches for supervision and alarm interpretation in industrial environment, *Proc. of ECC99*, Karlsruhe, 1999.
- Travé-Massuyès, L., Escobet, L., Pons, R., Tornil, R. (2001) The Ca-En diagnosis system and its automatic modeling method. *Computación i Sistemas Journal*, **5**, **2**, 128-143.
- Travé-Massuyès, L. and Dague, P. (2003) Modèles et raisonnements qualitatifs, chap. 7 : Raisonnement causal en physique qualitative, in *Traité IC2 « Information, Commande, Communications »*, Hermes.
- Unger, J., Kroner, A. and Marquadt W. (1995) Structural Analysis of differential-algebraic equation systems-theory and applications, *Computers chem. Engng*, **19**, **8**, 867-882.